

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013323.01-R2
DATE: 08/02/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Air Master
CODE: 2142-1
REVISION DATE: 08/17/2022

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Air Master Awning, LLC Road PR #2 interior KM 56.7 Barceloneta, PR 00617	Series "Rolling Window With Monolithic Glass" Aluminum Horizontal Sliding Window Configuration: OX Glazing: Monolithic-1/8" Annealed Glass/0.090" Eastman Chemical Saflex Interlayer/1/8" Annealed Glass Frame: W1880mm(74") H-1286mm(50.63") Panel: W938mm(36.94") H-1210mm(47.63") DLO: W-843mm(33.19") H-1148mm(45.19")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3352 Pa (70 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc.
Report No: BT-AM-16-001
Expiration Date: May 31, 2032

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be 'S.M.', written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com