

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013339.01  
DATE: 08/15/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Continental Glass  
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION   |
|---|---|
| <b>Continental Glass Systems, LLC</b><br><b>325 West 74 Place</b><br><b>Hialeah, FL 33014</b> | <b>Series "2200"</b><br><b>Aluminum Sliding Glass Door</b><br><b>w/Reinforcement</b><br><br>Configuration: OXXO<br>Glazing: IG-1/4" Tempered Glass/Laminate-1/4" Heat Strengthened Glass/0.090" Kuraray SentryGlas Plus Interlayer/1/4" Heat Strengthened Glass<br><br>Frame: W-5315mm(209.25") H-3131mm(123.25")<br>Panel: W-1346mm(53") H-3038mm(119.63")<br>DLO: W-1187mm(46.75") H-2845mm(112") |

| SPECIFICATION             | PRODUCT RATING  |
|---------------------------|---|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: 4309 Pa (90 psf)</b><br><b>Large Missile Impact Rated</b> |

Product Tested By: Fenestration Testing Laboratory, Inc  
Report No: FTL 5857  
Expiration Date: August 31, 2020

A handwritten signature in black ink, appearing to be 'S. D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122