WINDOW & DOOR MANUFACTURERS ASSOCIATION
WDMA

# Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Sierra Pacific Windows
11605 Reading Road
PO Box 8489
PO Box 8489
Red Bluff, CA 96080

*Mfr ID:* 448
*For more Information visit www.amscert.com*
*Website:*
*TEL:* 530-527-9620

| Product No. | Product Name | Standard | Rating | Wide | High | Test Report # | CertDate | ExpDate |
|---|---|---|---|---|---|---|---|---|
| 448-H-013.02 | 8000 Builders Vinyl Single Slider 72x60 | 101/I.S.2/A440-11 | Class R-PG20; Size Tested 1819mm x 1511mm Type-HS; DP +20/-20 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A2 | 1819mm | 1511mm | C2397.01-602-44 | 5/10/2016 | 9/24/2022 |

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

**By:** *John McFee, VP of Certification Programs, WDMA Hallmark*

**By:** *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com