

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016476.02
DATE: 03/10/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem/Silverline
CODE: 1408-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem/Silverline 5020 Weston Parkway Cary, North Carolina 27513	Series "70 Traditional/70RCW3" Vinyl Triple Outswing Casement Window Configuration: XXX Glazing: Insulating Glass (Annealed) Frame: W-2743mm(108") H-1829mm(72") Vent: W-879mm(34.63") H-1778mm(70") DLO: W-752mm(29.63") H-1651mm(65")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG30 2743 x 1829 (108 x 72)-C Design Pressure: ±1440 Pa (±30 psf) Water Penetration Resistance Test Pressure: 220 Pa (4.59 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-23744-1
Expiration Date: March 31, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023