

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016516.04
DATE: 02/20/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Silverline
CODE: 3108-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Silverline Building Products 5020 Weston Parkway Cary, NC 27513	Series "70" 70RPW1AW1V/70NPW1AW1V Vinyl Awning Window (Awning Under Fixed) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-2438mm(96") Vent: W-1168mm(46") H-772mm(30.38") DLO: W-1041mm(41") H-645mm(25.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	Class R-PG35 1219 x 2438 (48 x 96)-AP Design Pressure: ± 1680 Pa (± 35 psf) Water Penetration Resistance Test Pressure: 260 Pa (5.43 psf)

Product Tested By: Intertek, PLC
Report No: E5616.01-109-47
Expiration Date: February 28, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023