

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013431.01
DATE: 11/29/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "2000" Aluminum Sliding Glass Door w/Head Receptor & 3/8" Aluminum Reinforcement Configuration: OXXO Glazing: Monolithic Laminate-1/4"Tempered Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Tempered Glass or 1/4"Heat Strengthened Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Heat Strengthened Glass Frame: W-5182mm(204") H-3089mm(121.63") Panel: W-1346mm(53") H-2921mm(115") DLO: W-1187mm(46.75") H-2842mm(111.88")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 3830 Pa (80 psf) Small Missile Impact Rated

Product Tested By: Fenestration Testing Laboratory, Inc
Report No: FTL 4724/BT-CON-16-006/W-1794
Expiration Date: November 30, 2020

Administrator's Signature: 

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122