

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013431.07  
DATE: 11/28/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Continental Glass  
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Continental Glass Systems, LLC</b> <b>325 West 74 Place</b> <b>Hialeah, FL 33014</b>	<b>Series "2000"</b> <b>Aluminum Sliding Glass Door</b> <b>w/Standard Head</b>  Configuration: OXXO Glazing: Monolithic Laminate-1/4"Tempered Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Tempered Glass or 1/4"Heat Strengthened Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Heat Strengthened Glass  Frame: W-5182mm(204") H-3045mm(119.88") Panel: W-1346mm(53") H-2921mm(115") DLO: W-1187mm(46.75") H-2842mm(111.88")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: 2538 Pa (53 psf)</b> <b>Small Missile Impact Rated</b>

Product Tested By: Fenestration Testing Laboratory, Inc  
Report No: FTL 4724/BT-CON-16-006/W-1794  
Expiration Date: November 30, 2020

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/Fax: (804) 684-5122