

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013431.09  
DATE: 11/29/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: Continental Glass  
CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS  | PRODUCT DESCRIPTION  |
|---|--|
| <b>Continental Glass Systems, LLC</b><br><b>325 West 74 Place</b><br><b>Hialeah, FL 33014</b> | <b>Series "2000"</b><br><b>Aluminum Sliding Glass Door</b><br><b>w/Standard Head</b><br><b>&amp; 1/4" Steel Reinforcement</b><br><br>Configuration: OXXO<br>Glazing: Monolithic Laminate-1/4"Tempered Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Tempered Glass or 1/4"Heat Strengthened Glass/0.060" Eastman Saflex PVB Interlayer/1/4" Heat Strengthened Glass<br><br>Frame: W-5182mm(204") H-3045mm(119.88")<br>Panel: W-1346mm(53") H-2921mm(115")<br>DLO: W-1187mm(46.75") H-2842mm(111.88") |

| SPECIFICATION             | PRODUCT RATING   |
|---------------------------|--|
| <b>TAS 201/202/203-94</b> | <b>Design Pressure: 5267 Pa (110 psf)</b><br><b>Small Missile Impact Rated</b> |

Product Tested By: Fenestration Testing Laboratory, Inc  
Report No: FTL 4724/BT-CON-16-006/W-1794  
Expiration Date: November 30, 2020

Administrator's Signature: 

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124/Fax: (804) 684-5122