



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG50*-1324x1600 (52x63)-H Negative Design Pressure = -63 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	18894	1620 SH (FIN, FLANGE, & FINLESS) (PVC)(O/X)(OG) (INS 0.090" PVB LAM GL) (MODIF)(REINF)(TILT)(ASTM)	<u>FRAME</u> 1324 mm x 1600 mm (52" x 63")	<u>SASH</u> 1257 mm x 794 mm (50" x 31")
Design Pressure (psf): +55/-63 (Pa): +2640/-3050		Water Test Pressure (psf): 7.52 (Pa): 360		

This Certification will expire **March 19, 2030 (extended from March 19, 2025 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Molimo, LLC**

Report No.: **1919.02-106-12**

Date of Report: **March 24, 2020**

Date Test Completed: **March 19, 2020**

Evaluated for Certification: **April 20, 2020**


Associated Laboratories, Inc.

Authorized for Certification: **April 20, 2020**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)