



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

MI Windows & Doors, LLC
P.O. Box 370
Gratz, PA 17030-0370

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG35*-1219x2438 (48x96)-H Negative Design Pressure = -45 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
MI Windows & Doors, LLC Code: MTL	16574	1620/1621 SH (FIN, FLANGE, & FINLESS) (PVC)(O/X)(OG)(INS GL) (MODIF)(REINF)(TILT) (ASTM)	FRAME 1219 mm x 2438 mm (48" x 96")	SASH 1153 mm x 903 mm (45" x 36")
Design Pressure (psf): +45/-45 (Pa): +2160/-2160		Water Test Pressure (psf): 5.43 (Pa): 260		

This Certification will expire **March 24, 2027 (extended from March 24, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.


Product Tested and Reported by: **Intertek-ATI**

Report No.: **G9386.01-109-47**

Date of Report: **May 3, 2017**

Date Test Completed: **March 24, 2017**

Evaluated for Certification: **August 2, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **August 2, 2024**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)