

NOTICE OF PRODUCT CERTIFICATION



Company: Nan Ya Plastics Corporation
8989 North Loop East
Houston, TX 77029

Certification No.: NI010023-R5 Pg6
Certification Date: 09/09/2009
Expiration Date: 06/30/2035
Revision Date: 10/24/2023

Product: Series "NI-3" Fiberglass Skin Opaque Double Entry Door (PVC Frame)
Specification: TAS 202-94

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	O/S	Opaque	3'1" x 6'9"	+50/-55 psf	No	ETC-07-255-18448.5
X Single	I/S	Opaque	3'1" x 6'10"	+30/-50 psf	No	ETC-07-255-18448.5
XX Double	O/S	Opaque	6'2" x 6'9"	+50/-55 psf	No	ETC-07-255-18448.5
XX Double	I/S	Opaque	6'2" x 6'10"	+30/-50 psf	No	ETC-07-255-18448.5

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: 