NOTICE OF PRODUCT CERTIFICATION

Company: Nan Ya Plastics Corporation
4016 Shadrack St.
Houston, TX 77013

Certification No.: NI010023-R6 Pg4
Certification Date: 09/09/2009
Expiration Date: 06/30/2035
Revision Date: 06/18/2026

Product: Series "NI-1" Fiberglass Skin Glazed Double Entry Door w/ or w/o Sidelites (PVC Frame)
Specification: TAS 202-94
Glazing: IG: 1/8" Tempered Glass

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	O/S	Glazed	3'0" x 6'10"	+50/-50 psf	No	ETC-07-255-18448.5 Maximum DLO: 2'2" x 5'6"
XX Double	O/S	Glazed	6'0" x 6'10"	+50/-50 psf	No	ETC-07-255-18448.5 Maximum DLO: 2'2" x 5'6"
OX/XO Single w/Sidelite	O/S	Glazed	4'2" x 6'10"	+50/-50 psf	Door-No Sidelite-No	ETC-07-255-18448.5 Maximum DLO: 2'2" x 5'6"
OXO Single w/Sidelites	O/S	Glazed	5'4" x 6'10"	+50/-50 psf	Door-No Sidelite-No	ETC-07-255-18448.5 Maximum DLO: 2'2" x 5'6"
OXXO Double w/Sidelites	O/S	Glazed	8'9" x 6'10"	+50/-50 psf	Door-No Sidelite-No	ETC-07-255-18448.5 Maximum DLO: 2'2" x 5'6"

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____