



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG65-4978x2438 (196x96)-SD Negative Design Pressure = -70 psf	TAS 201, 202, 203				
COMPANY AND CODE	Missile Level: Large Rating: +65/-70, 196x96	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: TAS 201, TAS 202, and TAS 203	22040	PREMIUM VINYL (V-4500) MULTI-SLIDE SGD (FINLESS) (PVC)(XXXX)(OG) (INS TEMP/0.090" SGP LAM GLASS)(MODIF)(REINF) (ASTM)	FRAME (mm) 4978 x 2438 (196" x 96")	PANEL (mm) 1249 x 2369 (49" x 93")

This Certification will expire **December 21, 2031 (extended from December 21, 2026 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

National Certified Testing Laboratories

Report No: **NCTL-110-16-158**

Date of Report: **May 10, 2017**

Date Test Completed: **December 21, 2016**

Missile Impact Test & Report By:


National Certified Testing Laboratories

Report No: **NCTL-110-16-158**

Date of Report: **May 10, 2017**

Date Test Completed: **December 21, 2016**

Evaluated for Certification: **January 7, 2025**


Associated Laboratories, Inc.

Authorized for Certification: **January 7, 2025**



Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)