AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG60-7130x3050 (281x120)-SD	**TAS 201, 202, 203**				
COMPANY AND CODE	Missile Level: **Large** Rating: **+60/-60, 281x120**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: **TAS 201, TAS 202, and TAS 203**	**22045**	**PREMIUM VINYL (V-4500) MULTI-SLIDE SGD (FINLESS) (PVC)(XXXXXX)(OG) (INS TEMP/0.090" SGP LAM GLASS)(MODIF) (REINF)(ASTM)**	**FRAME (mm)** **7130 x 3050 (281" x 120")**	**PANEL (mm)** **1249 x 2978 (49" x 117")**

This Certification will expire **January 27, 2032 (extended from January 27, 2027 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Intertek-ATI

Report No: **G6556.02-301-47**

Date of Report: **April 11, 2017 (Revised June 12, 2017)**
Date Test Completed: **January 27, 2017**

Missile Impact Test & Report By:

Intertek-ATI

Report No: **G6556.02-301-47**

Date of Report: **April 11, 2017 (Revised June 12, 2017)**
Date Test Completed: **January 27, 2017**

Evaluated for Certification: **January 7, 2025**

Associated Laboratories, Inc.

Authorized for Certification: **January 7, 2025**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)