

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013410-R2  
DATE: 11/08/2016  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 02/07/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS                                                              | PRODUCT DESCRIPTION                                                                                                                                                                                                                                                                                                    |
|---------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>JELD-WEN Doors</b><br><b>3737 Lakeport Drive</b><br><b>Klamath Falls, OR 97601</b> | <b>Series "Aurora Custom Fiberglass"</b><br><b>Out-Swing Glazed Full-Lite Fiberglass</b><br><b>Side Hinged Door</b><br><br>Configuration: X<br>Glazing: Insulating Glass (Tempered)<br>Frame: W-1260mm(49.61") H-3090mm(121.65")<br>Panel: W-1215mm(47.83") H-3041mm(119.72")<br>DLO: W-960mm(37.8") H-2703mm(106.42") |

| SPECIFICATION                                       | PRODUCT RATING                                                                                                                                                                                       |
|-----------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>ASTM E283-04(12)/E330-02/14/<br/>E331-00(09)</b> | <b>Positive Design Pressure: <math>\pm 2400</math> Pa (50 psf)</b><br><b>Negative Design Pressure: <math>\pm 3120</math> Pa (65 psf)</b><br>Water Penetration Resistance Test Pressure: 0 Pa (0 psf) |

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-16-119  
Expiration Date: August 31, 2028

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122