NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013411-R2**
DATE:	**11/08/2016**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**02/07/2020**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN Doors **3737 Lakeport Drive** **Klamath Falls, OR 97601**	**Series "Aurora Custom Fiberglass"** **In-Swing Glazed Full-Lite Fiberglass** **Side Hinged Door** Configuration: X Glazing: Insulating Glass (Tempered) Frame: W-1260mm(49.61") H-3090mm(121.65") Panel: W-1215mm(47.83") H-3021mm(118.94") DLO: W-960mm(37.8") H-2703mm(106.42")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-02/14/ E331-00(09)	**Positive Design Pressure: ±2400 Pa (50 psf)** **Negative Design Pressure: ±3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-16-120
Expiration Date: **August 31, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122