

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013877.09-R2
DATE: 01/17/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 02/07/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Opaque Fiberglass Out-Swing Side-Hinged Door Configuration: XX Frame: W-2487mm(97.91") H-3088mm(121.57") Panel: W-1213mm(47.76") H-3021mm(118.94")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-14/E331-00(16) ASTM E547-00(16) AAMA 1304-02	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17-155/W-1880
Expiration Date: July 31, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122