

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013907.06-R1
DATE: 03/21/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 03/21/2018

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Full Lite Out-Swing Side-Hinged Door Assembly Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-2485mm(97.81") H-3090mm(121.63") Panel: W-1235mm(48.63") H-3030mm(119.31") DLO: W-980mm(38.56") H-2734mm(107.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG50 2485 x 3090(98 x 122) LW SHD Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Intertek
Report No: I1290.02-301-47
Expiration Date: March 31, 2026

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com