

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI015688
DATE: 11/07/2022
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Glazed Fiberglass Inswing Double Side-Hinged Door (w/Sidelites) Configuration: OXXO Glazing: Tempered Frame: W-3785mm(149") H-3092mm(121.75") Panel: W-1213mm(47.75") H-3016mm(118.75") DLO: W-886mm(34.88") H-2800mm(110.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 CSA A440S1-17	Class LC PG50 3785 x 3092(149 x 122)-LW SHD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Canadian Air Infiltration/Exfiltration Level : A3

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-310-22-065/NCTL-310-22-081
Expiration Date: August 31, 2025

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com