

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013479.02-R4
DATE: 01/24/2017
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 02/07/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	"Aurora" Glazed In-Swing or Out-Swing Fiberglass Side-Hinged Door Configuration: X Glazing: IG-3/16" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-1259mm(49.56") H-3090mm(121.75") Panel: W-1215mm(47.81") H-3049mm(120.06") DLO: W-729mm(28.68") H-1747mm(68.75")

SPECIFICATION	PRODUCT RATING
ASTM E330-02/E330M-14 ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf) Wind Zone 3 - Missile Level D

Product Tested By: Architectural Testing, Incorporated
Report No: G4608.07-301-47/W-1894
Expiration Date: **October 31, 2028**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122