NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013907.04-R2**
DATE:	**01/08/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**03/11/2020**

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Aurora Custom" Opaque** **Fiberglass In-Swing French** **Double Door Assembly** Configuration: XX Frame: W-2487mm(97.91") H-3088mm(121.57") Panel: W-1213mm(47.76") H-3021mm(118.94")

SPECIFICATION	PRODUCT RATING
ASTM E283-04(12)/E330-14 **ASTM E547-00(16)** **ASTM E1886-05/13a** **ASTM E1996-12a/14a**	**Design Pressure: 2400 Pa (50 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 3120 Pa (65 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)** **Wind Zone 4 - Missile Level D**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-17-096/W-1894
Expiration Date: **September 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122