

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013907.08-R3
DATE: 05/24/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 03/11/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Glazed TDL Full Lite In-Swing Side-Hinged Door Assembly Configuration: XX Glazing: IG-5/32" Tempered Glass/1/8" Annealed Glass/0.090" Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-2489mm(98") H-3092mm(121.75") Panel: W-1238mm(48.69") H-3048mm(120") DLO: W-979mm(38.56") H-2730mm(107.5")

SPECIFICATION	PRODUCT RATING
ASTM E330/E330M-14 ASTM E331-00(09)(16) ASTM E1886-05/13a ASTM E1996-09/12a/14a	Design Pressure: ±2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3120 Pa (65 psf) Wind Zone 3 - Missile Level D Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: Intertek Building & Construction, PLC
Report No: I3522.01-301-47/I3605.01-301-47/W-1894
Expiration Date: April 30, 2030

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122