

Hallmark® Certificate of Conformance and License (CCL)



Weather Shield Mfg. Inc.
1 Weathershield Plaza
PO Box 309
PO Box 309
Medford, WI 54451-0309

Mfr ID: 449
For more Information visit www.amscert.com
Website: www.weathershield.com
TEL: 715-748-2100

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
449-H-095.09	Contemporary Inswing Door with Mulled Sidelight (8517) 86"x98"	101/I.S.2/A440-11	Class LC-PG25; Size Tested 1105mm trib width x 2489mm span Type-MA; DP +50/-50 psf; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	1105mm trib width	2489mm span	ESP021759P-1829	9/21/2016	1/21/2026

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com