

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1069.39	Heritage Gardenaire Sliding Patio Door, 8-0x8-0, SP, Narrow Stiles and Rails, (R&D 23041 Re-Cert 13113)	101/I.S.2/A440-22	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +45/-45 psf; Water Test Press 330Pa (6.89psf)	2438mm	2500mm	QCT25-7496.12	7/7/2025	7/25/2025	5/19/2035
413-H-1069.40	Heritage Gardenaire Sliding Patio Door, 8-0x8-0, SP, Narrow Stiles and Rails, (R&D 23041 Re-Cert 13113)	101/I.S.2/A440-17	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +45/-45 psf; Water Test Press 330Pa (6.89psf)	2438mm	2500mm	QCT25-7496.12	7/7/2025	7/25/2025	5/19/2035
413-H-1069.42	Heritage Gardenaire Sliding Patio Door, 8-0x8-0, SP, Narrow Stiles and Rails, (R&D 23041 Re-Cert 13113)	CSA A440 S1-19	Class LC-PG45; Size Tested 2438mm x 2500mm Type-SD; DP +2160/-2160 psf; Water Test Press 330Pa (6.89psf); Can. Air Infil/Exfil. Level=A3	2438mm	2500mm	QCT25-7496.12	7/7/2025	7/25/2025	5/19/2035
413-H-1070.156	Vistaluxe Stretta Sliding Door, 4 Wide with Direct Set Panel, SP (R&D 24106)	101/I.S.2/A440-22	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	4799mm	2505mm	QCT25-7496.13	7/15/2025	7/25/2025	6/18/2035
413-H-1070.157	Vistaluxe Stretta Sliding Door, 4 Wide with Direct Set Panel, SP (R&D 24106)	101/I.S.2/A440-17	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	4799mm	2505mm	QCT25-7496.13	7/15/2025	7/25/2025	6/18/2035
413-H-1070.158	Vistaluxe Stretta Sliding Door, 4 Wide with Direct Set Panel, SP (R&D 24106)	CSA A440 S1-19	Class LC-PG30; Size Tested 4799mm x 2505mm Type-SD; DP +1440/-1440 Pa; Water Test Press 220Pa (4.59psf); Can. Air Infil/Exfil. Level=A3	4799mm	2505mm	QCT25-7496.13	7/15/2025	7/25/2025	6/18/2035
413-H-1121.33	Ultra EP Pushout Awning, SP, Frame Size 48x48 (R&D 25050 Recert 15006)	101/I.S.2/A440-22	Class LC-PG55; Size Tested 1219mm x 1219mm Type-AP; DP +55/-55 psf; Water Test Press 400Pa (8.35psf)	1219mm	1219mm	QCT25-7496.11	7/7/2025	7/25/2025	5/15/2035
413-H-1121.34	Ultra EP Pushout Awning, SP, Frame Size 48x48 (R&D 25050 Recert 15006)	101/I.S.2/A440-17	Class LC-PG55; Size Tested 1219mm x 1219mm Type-AP; DP +55/-55 psf; Water Test Press 400Pa (8.35psf)	1219mm	1219mm	QCT25-7496.11	7/7/2025	7/25/2025	5/15/2035
413-H-1121.35	Ultra EP Pushout Awning, SP, Frame Size 48x48 (R&D 25050 Recert 15006)	CSA A440 S1-19	Class LC-PG55; Size Tested 1219mm x 1219mm Type-AP; DP +2640/-2640 psf; Water Test Press 400Pa (8.35psf); Can. Air Infil/Exfil. Level=A3	1219mm	1219mm	QCT25-7496.11	7/7/2025	7/25/2025	5/15/2035

Hallmark® Certificate of Conformance and License (CCL)



Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413

For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
413-H-1131.19	Ultra EP Pushout Casement, HP, Frame Size 36x72, Multi Point (R&D 25048 Recert 15005)	101/I.S.2/A440-22	Class CW-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	914mm	1829mm	QCT25-7496.09-R1	7/14/2025	7/25/2025	6/23/2035
413-H-1131.20	Ultra EP Pushout Casement, HP, Frame Size 36x72, Multi Point (R&D 25048 Recert 15005)	101/I.S.2/A440-17	Class CW-PG65; Size Tested 914mm x 1829mm Type-C; DP +65/-65 psf; Water Test Press 470Pa (9.82psf)	914mm	1829mm	QCT25-7496.09-R1	7/14/2025	7/25/2025	6/23/2035
413-H-1131.21	Ultra EP Pushout Casement, HP, Frame Size 36x72, Multi Point (R&D 25048 Recert 15005)	CSA A440 S1-19	Class CW-PG65; Size Tested 914mm x 1829mm Type-C; DP +3120/-3120 Pa; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	914mm	1829mm	QCT25-7496.09-R1	7/14/2025	7/25/2025	6/23/2035
413-H-1284.42	Ultra Folding Door, 6 wide LLLRRR, SP (R&D 23038 New)	101/I.S.2/A440-22	Class LC-PG30; Size Tested 6109mm x 3178mm Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	6109mm	3178mm	QCT23-7062.03	7/7/2025	7/25/2025	1/9/2035
413-H-1284.43	Ultra Folding Door, 6 wide LLLRRR, SP (R&D 23038 New)	101/I.S.2/A440-17	Class LC-PG30; Size Tested 6109mm x 3178mm Type-FLD; DP +30/-30 psf; Water Test Press 220Pa (4.59psf)	6109mm	3178mm	QCT23-7062.03	7/7/2025	7/25/2025	1/9/2035
413-H-1284.44	Ultra Folding Door, 6 wide LLLRRR, SP (R&D 23038 New)	CSA A440 S1-19	Class LC-PG30; Size Tested 6109mm x 3178mm Type-FLD; DP +1440/-1440 Pa; Water Test Press 220Pa (4.59psf); Can. Air Infil/Exfil. Level=A3	6109mm	3178mm	QCT23-7062.03	7/7/2025	7/25/2025	1/9/2035
413-H-1303.09	Ultra Folding Window 6-wide LLLRRR, SP (R&D 24062 Recert 14027)	101/I.S.2/A440-22	Class -PG25; Size Tested 6109mm x 1959mm Type-SP; DP +25/-25 psf; Water Test Press 216Pa (4.50psf)	6109mm	1959mm	QCT25-7523.01	7/7/2025	7/25/2025	4/1/2035
413-H-1303.10	Ultra Folding Window 6-wide LLLRRR, SP (R&D 24062 Recert 14027)	101/I.S.2/A440-17	Class -PG25; Size Tested 6109mm x 1959mm Type-SP; DP +25/-25 psf; Water Test Press 216Pa (4.50psf)	6109mm	1959mm	QCT25-7523.01	7/7/2025	7/25/2025	4/1/2035
413-H-1303.11	Ultra Folding Window 6-wide LLLRRR, SP (R&D 24062 Recert 14027)	CSA A440 S1-19	Class -PG25; Size Tested 6109mm x 1959mm Type-SP; DP +1200/-1200 Pa; Water Test Press 216Pa (4.50psf); Can. Air Infil/Exfil. Level=A3	6109mm	1959mm	QCT25-7523.01	7/7/2025	7/25/2025	4/1/2035

Hallmark® Certificate of Conformance and License (CCL)



AMS, INC.
Administrative Management
Systems, Inc.

Kolbe & Kolbe Millwork Co.
1323 South 11th Avenue
Wausau, WI 54401

Mfr ID: 413


For more Information visit www.amscert.com

Website: www.kolbewindows.com

TEL:

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
-------------	--------------	----------	--------	------	------	---------------	---------	----------	---------

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com