

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013482  
DATE: 01/18/2017  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176 HRP 3-3-3" Vinyl Horizontal Slider (Fin Installation) Configuration: XOX Glazing: Insulating Glass (Annealed)  Frame: W-2819mm(111") H-1600mm(63") Panel: W-937mm(36.88") H-1538mm(60.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG55 2819 x 1600 (111 x 63)-HS Design Pressure: $\pm 2640$ Pa (55 psf) Water Penetration Resistance Test Pressure: 504 Pa(10.5 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-4039-04  
Expiration Date: September 30, 2020

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'MD', is written over a horizontal line.

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122