

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016959
DATE: 04/22/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176" Vinyl Horizontal Slider (Fin & Finless) Configuration: X Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-2134mm(84") Sash: W-906mm(35.69") H-2067mm(81.38") DLO: W-819mm(32.25") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class LC-PG35 1829 x 2134 (72 x 84)-HS Design Pressure: ±1680 Pa (±35 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Molimo, LLC
Report No: 32724.01-106-12
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023