

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013481.01
DATE: 01/24/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "176" Vinyl Fixed Window (Fin or Flange Installation) Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2134mm(84") DLO: W-1708mm(67.25") H-2013mm(79.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class CW-PG90 1829 x 2134 (72 x 84)-FW Design Pressure: ±4320 Pa (90 psf) Water Penetration Resistance Test Pressure: 720 Pa(15 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4044-01A
Expiration Date: September 30, 2020

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122