

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013310.01-R3
DATE: 07/21/2016
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 06/18/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 4016 Shadrack St. Houston, TX 77013	Series "SLPS" Inswing Glazed Fiberglass Side-Hinged Patio Door (Impact) Configuration: OXX/O Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-3594mm(141.5") H-2419mm(95.25") Panel: W-876mm(34.5") H-2338mm(92.06") DLO: W-533mm(21") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05 ASTM E1996-05/09 AAMA/WDMA/CSA 101/I.S.2/A440-08 CSA A440S1-09	Class R-PG40 3594 x2419 (142 x 95)-SHD Design Pressure: ±1920 Pa (40 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 288 Pa (6.0 psf) Canadian Air Infiltration/Exfiltration Level: A2 Wind Zone 4 - Missile Level D Qualifies Configurations: O/X/OX/XO/OXX/XXO/O/O/X/O/O/X/OX/O/XO/O/OXX/O/O/XXO

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4020-02
Expiration Date: May 31, 2032

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124/ Email: nami@namiinc.com

NOPC-03/30/2023