



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAA/WDMA/CSA 101/I.S.2/A440-17 LC-PG50-1522x1522 (60x60)-FW Negative Design Pressure = -55 psf	AAMA 506			
COMPANY AND CODE	Missile Level: D Rating: +50/-55, 60x60 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: ASTM E1886 and E1996	16423	PREMIUM VINYL (V-4500) PW W/TRACK FILLER (FIN & FINLESS) (PVC)(O)(OG) (INS 0.090" PVB LAM GL) (MODIF)(ASTM)	<u>FRAME</u> 1522 mm x 1522 mm (60" x 60")

This Certification will expire **January 12, 2032 (extended from January 12, 2027)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Intertek-ATI

Report No: **G6813.07-301-47**

Date of Report: **March 23, 2017**

Date Test Completed: **January 12, 2017**

Missile Impact Test & Report By:


Intertek-ATI

Report No: **G6813.07-301-47**

Date of Report: **March 23, 2017**

Date Test Completed: **January 12, 2017**

Evaluated for Certification: **March 30, 2026**


Associated Laboratories, Inc.

Authorized for Certification: **March 30, 2026**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)