



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 LC-PG50-1219x1953 (48x77)-H Negative Design Pressure = -55 psf	AAMA 506				
COMPANY AND CODE	Missile Level: C Rating: +50/-55, 48x77 Wind Zone: 2	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: ASTM E1886 and E1996	16978	PREMIUM VINYL (V-4500) DH (FIN & FINLESS) (PVC)(X/X)(OG) (INS 0.060" PVB LAM GL) (MODIF)(REINF)(TILT)(ASTM)	FRAME (mm) 1219 x 1953 (48" x 77")	SASH (mm) 1153 x 968 (45" x 38")

This Certification will expire **February 6, 2032 (extended from February 6, 2027)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Element Materials Technology

Report No: **ESP024843P.6Rev**

Date of Reports: **March 15, 2017 (Revised May 16, 2017)**

Date Test Completed: **February 6, 2017**

Missile Impact Test & Report By:


National Certified Testing Laboratories

Report No: **NCTL-110-17-126**

Date of Report: **September 27, 2017**

Date Test Completed: **August 21, 2017**

Evaluated for Certification: **March 30, 2026**


Associated Laboratories, Inc.

Authorized for Certification: **March 30, 2026**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)