



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1219x914 (48x36)-AP Negative Design Pressure = -55 psf	AAMA 506				
COMPANY AND CODE	Missile Level: C Rating: +50/-55, 48x36 Wind Zone: 2	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: ASTM E1886 and E1996	18200	PREMIUM VINYL (V-4500) ROTARY OPERATED AWNING (FIN & FINLESS) (PVC)(X)(OG) (INS 0.030" PVB LAM GL) (MODIF)(REINF)(ASTM)	<u>FRAME (mm)</u> 1219 x 914 (48" x 36")	<u>VENT (mm)</u> 1181 x 876 (46" x 34")

This Certification will expire **February 26, 2028 (extended from February 26, 2023 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

National Certified Testing Laboratories

Report No: **SJW2015-146; ref. NCTL-310-4012**

Date of Reports: **January 12, 2016; February 27, 2014**

Date Tests Completed: **December 2, 2015; February 26, 2014**

Missile Impact Test & Report By:


National Certified Testing Laboratories

Report No: **SJW2015-146**

Date of Report: **January 12, 2016**

Date Test Completed: **December 2, 2015**

Evaluated for Certification: **January 7, 2025**


Associated Laboratories, Inc.

Authorized for Certification: **January 7, 2025**



Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)