NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013674.02-R3**
DATE:	**04/03/2017**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Comfort View**
CODE:	**2111-1**
REVISION DATE:	**04/01/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC **320 Coweta Industrial Park** **Building 7, Suite C-1** **Newnan, GA 30265**	**Series "901/951"** **Vinyl Fixed Window** Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1219mm(48") H-1829mm(72") DLO: W-1092mm(43") H-1702mm(67")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 **AAMA/WDMA/CSA 101/I.S.2/A440-08** **AAMA/WDMA/CSA 101/I.S.2/A440-05**	**Class CW-PG55 1219 x 1829* (48 x 72*)-FW** **FW-C55 1219 x 1829* (48 x 72*)** **Design Pressure: ±2640 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 580 Pa (12.11 psf)**

Product Tested By: Architectural Testing, Inc.
Report No: E8069.02-501-47
Expiration Date: **May 31, 2036**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com