

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013478.09-R3
DATE: 01/17/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Comfort View
CODE: 2111-1
REVISION DATE: 01/29/2024

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Comfort View Products, LLC 320 Coweta Industrial Park Building 7, Suite C-1 Newnan, GA 30265	Series "900/950 CHS Twin" Mulled Vinyl Single Hung Window Assembly w/Reinforced Integral Mullion Configuration: O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.5") H-1511mm(59.5") Sash: W-827mm(32.56") H-733mm(28.88") DLO: W-783mm(30.81") H-667mm(26.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG50 1829 x 1524* (72 x 60*)-H Design Pressure: ± 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: F9512.02-501-47/F5687.02-501-47/W-1892
Expiration Date: **June 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC 03/30/2023