



FGIA®
Fenestration & Glazing
Industry Alliance

AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-17 R-PG50-2742x1829 (108x72)-C Negative Design Pressure = -55 psf	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +50/-55, 108x72 Wind Zone: 3	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	Rating above conforms to the requirements of: ASTM E1886 and E1996	16571	PREMIUM VINYL (V-4500) ROTARY OPERATED TRIPLE CASEMENT (FIN & MASONRY STRAPS) (PVC)(XXX)(OG) (INS 0.090" PVB LAM GL) (MODIF)(REINF)(ASTM)	FRAME (mm) 2742 x 1829 (108" x 72")	VENT (mm) 874 x 1791 (34" x 70")

This Certification will expire **February 18, 2028 (extended from January 27, 2027 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

National Certified Testing Laboratories

Report No: **SJW2013-243, SJW2014-031, & SJW2014-037**

Date of Reports: **December 2, 2013; March 14, 2014, & April 28, 2014**

Date Tests Completed: **October 31, 2013; February 18, 2014; April 2, 2014**

Missile Impact Test & Report By:


National Certified Testing Laboratories

Report No: **NCTL-110-17-025**

Date of Report: **May 1, 2017**

Date Test Completed: **January 27, 2017**

Evaluated for Certification: **July 25, 2025**


Associated Laboratories, Inc.

Authorized for Certification: **July 25, 2025**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

A.L.I.

(Validator / Operations Administrator)