

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
1955 Powis Road
West Chicago, IL 60185

Certification No.: NI007077.06-R8
Certification Date: 05/04/2017
Expiration Date: 12/31/2029
Revision Date: 09/09/2026

Product: Fiberglass Impact Rated Glazed Inswing or Outswing Door w/ and w/o Impact Rated Sidelites
Endura Trilennium or Panolock Multipoint Hardware
(w/Wood Frame or Worldwide Composite Frame⁴ unless noted)

Specification: TAS 201/202/203-94/ASTM E330-02/14/M-14

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 6'8"	+50/-50	0 psf	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1885/W-2106/W-2107
X Single	O/S	Glazed	3'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵ /9.0 psf ⁶	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1835/W-1885/W-2106/W-2107/W-2203
XX Double	I/S	Glazed	6'0" x 6'8"	+50/-50	0 psf	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1885
XX Double	O/S	Glazed	6'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /8.25 psf ⁵ /8.25 psf ⁶	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1835/W-1885/W-2106/W-2107/W-2203
XO/OX Single w/Sidelite	I/S	Glazed Door Glazed Sidelite	6'0" x 6'8"	+50/-50	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1885/W-2106/W-2107
XO/OX Single w/Sidelite	O/S	Glazed Door Glazed Sidelite	6'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵ /8.25 psf ⁶	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1835/W-1885/W-2106/W-2107/W-2203
OXO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	9'0" x 6'8"	+50/-50	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1885/W-2106/W-2107
OXO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	9'0" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /9.0 psf ⁵ /8.25 psf ⁶	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1835/W-1885/W-2106/W-2107/W-2203
OXOX Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	12'4" x 6'8"	+50/-50	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1885/W-2106/W-2107
OXOX Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	12'4" x 6'8"	+50/-50	3.75 psf ¹ /6.0 psf ² 8.25 psf ³ /8.25 psf ⁵	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 6'8"/Sidelite: 3'0" x 6'8" Anchor Details-MA-FL0185-17/W-1807/W-1835/W-1885/W-2106/W-2107

1 -Denotes Bumper Outswing Threshold Design 2 -Denotes Z-Series Outswing Threshold Design 3 -Denotes High Dam Outswing Threshold Design 4-W-1815 5-Denotes Worldwide Pro T4 Threshold 6-Denotes HPB OS

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____