

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013699-R2
DATE: 05/04/2017
CERTIFICATION PROGRAM: Structural
COMPANY: ProVia Door
CODE: 1212-1
REVISION DATE: 09/16/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia, LLC 2150 State Route 39 Sugarcreek, OH 44681	Series "165.000 PW" Vinyl Fixed Window (Installation: Fin or Flange/Equal Leg) Configuration: O Glazing: IG-Ext-3/16" Annealed Glass/Int-Laminate-1/8" Annealed Glass/0.090" Trosifol PVB Interlayer by Kuraray America/1/8" Annealed Glass Frame: W-1372mm(54") H-1956mm(77") DLO: W-1251mm(49.25") H-1835mm(72.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/ASTM E1996-05/09	Class R-PG50 1372 x 1956 (54 x 77)-FW Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3840 Pa (80 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf) ASTM Rating: Design Pressure: ±2400 Pa (50 psf) Wind Zone 4-Missile Level D

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4074-01/NCTL-210-4074-04
Expiration Date: November 30, 2024

Administrator's Signature: _____

**NATIONAL ACCREDITATION &
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122