



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
**1 Cochrane Dr.**  
**Pennsboro, WV 26415**

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG55-762x1651 (30x65)-C	AAMA 506				
COMPANY AND CODE	Missile Level: <b>D</b> Rating: <b>+55/-55, 30x65</b> Wind Zone: <b>4</b>	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: <b>SIM</b>	Rating above conforms to requirements of: <b>ASTM E1886</b> <b>and E1996</b>	<b>5317</b>	<b>08-09 STORM BREAKER PLUS CASEMENT (PVC)(X)(OG) (INS TEMP/0.090" PVB LAM GL) (MODIF)(ASTM</b>	<u><b>FRAME (mm)</b></u> <b>762 x 1651</b> <b>(30" x 65")</b>	<u><b>VENT (mm)</b></u> <b>718 x 1601</b> <b>(28" x 63")</b>

This Certification will expire **September 14, 2029 (extended from September 14, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Architectural Testing, Inc.**

Report No: **A4519.01-501-47**

Date of Report: **October 15, 2010**

Date Test Completed: **October 5, 2010**

Missile Impact Test & Report By:


**Architectural Testing, Inc.**

Report No: **A8094.01-501-47; ref. A2065.01-501-47**

Date of Reports: **July 13, 2011; October 6, 2010 (Revised May 25, 2012)**

Date Tests Completed: **June 7, 2011; September 14, 2010**

Evaluated for Certification: **June 11, 2024**

  
Associated Laboratories, Inc.

Authorized for Certification: **June 11, 2024**



Fenestration and Glazing Industry Alliance  
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)