

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
1955 Powis Road
West Chicago, IL 60185

Certification No.: NI013747.05-R4
Certification Date: 06/08/2017
Expiration Date: 06/30/2027
Revision Date: 11/14/2023

Product: Wood-Edge Steel Glazed Inswing or Outswing Door w/Non-Impact Rated Sidelites
(w/Wood Frame unless noted)

Specification: ASTM E330-02/14/M-14

Glazing: Insulating Glass (Tempered)

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
X Single	O/S	Glazed	3'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
XX Double	O/S	Glazed	6'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
XO/OX Single w/Sidelite	I/S	Glazed	6'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
XO/OX Single w/Sidelite	O/S	Glazed	6'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
OXO Single w/Sidelites	I/S	Glazed	9'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
OXO Single w/Sidelites	O/S	Glazed	9'0" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
OXOX Double w/Sidelites	I/S	Glazed	12'4" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17
OXOX Double w/Sidelites	O/S	Glazed	12'4" x 8'0"	+40/-40	ATLNC 0920.01-16/W-1961/W-2094 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" Anchor Details-DWG-MA-FL0216-17

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: