

	Document Title: Structural Performance Certification Authorization Report	Doc No: FRM B1-02	
		Rev No: 7	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 1127 - 101.0
Issue Date: 10/23/2017
Revision Date: 8/31/2021
Expiration Date: 10/23/2024
Company Code: 1127

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information: Glass Flooring Systems, Inc. 10 Leslie Court Whippany, NJ 07981 USA	Product Information: Model: SkyFloor Walkable Skylight-FA-TB 4x4 Operator Type: SKG Config: No, GS-1-5/8" Temp IG Max Width: 48 Max Height: 48
Referenced Standard: AAMA/WDMA/CSA 101/I.S.2/A440-11	Product Rating: Class CW-PG120 1216x1216 (48x48)-Type SKG DP=-140
Qualifying Test Information:	
Test Report No: NCTL-110-19383-1 Test Report Expiration: 10/23/2024	

Authorized Signature:

Aaron Shultz
'00'04- 09:42:08 2021.08.31




Validations Manager

Keystone Certifications, Inc.

145 Limekiln Rd. Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501