

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 1127 - 201

Issue Date: 10/23/2017

Revision Date: 8/31/2021

Expiration Date: 10/23/2024

Company Code: 1127

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Glass Flooring Systems, Inc. 10 Leslie Court Whippany, NJ 07981 USA	Model: SkyFloor Walkable Skylight-FA-TB 4x4 Operator Type: SKG Config: No, GS-1-5/8" Temp IG Max Width: 48 Max Height: 48 Corresponding Structural CARs: 1127-101

Referenced Standard:	Product Rating:
STME1886/E1996-02/04/05/06/09/12/13a/14	Missile Level D, Wind Zone 4, DP+/-120, 48x48, O

Qualifying Test Information:	
Test Report No:	NCTL-110-19383-3
Test Report Expiration:	10/23/2024

Authorized Signature:

Aaron Shultz

10:26:05 2021.08.31

'00'04-




Keystone Certifications, Inc.

145 Limekiln Rd., Suite 100B

New Cumberland, Pennsylvania 17070

Phone: 717-932-8500

Fax: 717-932-8501