

AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS | | RECORD OF PRODUCT TESTED | | |
|--|---|--------------------------|--|---|
| AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50*-940x2134 (37x84)-FW | AAMA 506 | | | |
| COMPANY AND CODE | Missile Level: D Rating: +50/-50, 37x84 Wind Zone: 4 | CPD NO. | SERIES MODEL & PRODUCT DESCRIPTION | MAXIMUM SIZE TESTED |
| Simonton Windows Code: SIM | Rating above conforms to the requirements of: ASTM E1886 and E1996 | 5316 | 07-09 PW (PVC)(O)(IG) (INS TEMP/0.090" PVB LAM GL) (ASTM) | FRAME 940 mm x 2134 mm (3'1" x 7'0") |

This Certification will expire **June 23, 2024 (extended from June 23, 2019 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc.

Report No: **A2066.01-501-44**

Date of Report: **July 7, 2010**


Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **99620.01-501-47**

Date of Report: **August 30, 2010 (Revised May 30, 2012)**

Evaluated for Certification: April 16, 2019


 Associated Laboratories, Inc.

Date: **March 24, 2016**

Authorized for Certification: April 16, 2019

Cc: AAMA

JGS

ACP-14 (Rev. 1/11)



American Architectural Manufacturers Association