



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50*-940x2134 (37x84)-FW	AAMA 506			
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 37x84 Wind Zone: 4 Rating above conforms to the requirements of: ASTM E1886 and E1996	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED
Simonton Windows Code: SIM		5316	07-09 PW (PVC)(O)(IG) (INS TEMP/0.090" PVB LAM GL) (ASTM)	FRAME 940 mm x 2134 mm (37" x 84")

This Certification will expire **June 23, 2029 (extended from June 23, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc.

Report No: **A2066.01-501-44**

Date of Report: **July 7, 2010**

Date Test Completed: **June 23, 2010**

Missile Impact Test & Report By:


Architectural Testing, Inc.

Report No: **99620.01-501-47**

Date of Report: **August 30, 2010 (Revised May 30, 2012)**

Date Test Completed: **August 2, 2010**

Evaluated for Certification: **January 22, 2024**


Associated Laboratories, Inc.

Authorized for Certification: **January 22, 2024**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)