

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013712.01-R1
DATE: 05/10/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Continental Glass
CODE: 2103-1
REVISION DATE: 09/18/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC 325 West 74 Place Hialeah, FL 33014	Series "3020" Aluminum Fixed Window Wall System Configuration: OO/OO Glazing: Monolithic Laminate-3/16" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or IG (WET)-Laminate-3/16" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/3/16" Heat Strengthened Glass/3/16" Tempered Glass or Monolithic Laminate-1/4" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/1/4" Heat Strengthened Glass or IG-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or Monolithic Laminate (WET)-3/16" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or IG (WET)-3/16" Tempered Glass/Laminate-3/16" Heat Strengthened Glass/0.090" Butacite PVB Interlayer/3/16" Heat Strengthened Glass Frame: W-3912mm(154") H-3048mm(120") DLO: W-1219mm(48") H-2921mm(115")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 4309 Pa (90 psf) Large Missile Impact Rated

Product Tested By: Blackwater Testing, Inc
Report No: BT-CON-16-003/W-1834
Expiration Date: March 31, 2021

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/ Fax: (804) 684-5122