NOTICE OF PRODUCT CERTIFICATION •



CERTIFICATION NO: NI013712.08

DATE: <u>05/10/2017</u>

CERTIFICATION PROGRAM: Structural

COMPANY: Continental Glass

CODE: 2103-1

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status.

Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Continental Glass Systems, LLC	Series "3020"
325 West 74 Place	Aluminum Fixed Window Wall System
Hialeah, FL 33014	Configuration: O/O Glazing: Monolithic Laminate-3/16"Heat Strengthened Glass/0.060" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or Monolithic Laminate-3/16"Heat Strengthened Glass/0.060" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Tempered Glass/Laminate-3/16"Heat Strengthened Glass/0.060" Butacite PVB Interlayer/3/16" Heat Strengthened Glass or Monolithic Laminate (WET)-3/16"Heat Strengthened Glass or IG (WET)-Laminate-3/16"Heat Strengthened Glass or IG (WET)-Laminate-3/16"Heat Strengthened Glass/0.060" Butacite PVB Interlayer/3/16" Heat Strengthened Glass/3/16" Tempered Glass or IG (WET)-3/16" Tempered Glass/Laminate-3/16"Heat Strengthened Glass/0.060" Butacite PVB Interlayer/3/16" Heat Strengthened Glass
	Frame: W-2438mm(96") H-2629mm(103.5")
	DLO: W-2311mm(91") H-1219mm(48")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: 2873 Pa (60 psf) Small Missile Impact Rated

Product Tested By: Blackwater Testing, Inc Report No: BT-CON-16-003/W-1834

Expiration Date: March 31, 2021

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124/ Fax: (804) 684-5122