

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013908-R1
DATE: 12/27/2017
CERTIFICATION PROGRAM: Structural
COMPANY: Optimum
CODE: 1742-1
REVISION DATE: 04/21/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Optimum Window Manufacturing Corporation 28 Canal Street Ellenville, NY 12428	Series "FR7650TSHi" Steel Single Hung Window Configuration: O/X Glazing: IG-1/8" Tempered Glass/3/16" Firelite Plus Hurricane® Ceramic Glass/0.090" Kuraray SGP Interlayer/3/16" Firelite Plus Hurricane® Ceramic Glass Frame: W-1029mm(40.5") H-2438mm(96") Sash: W-965mm(38") H-1257mm(49.5") DLO: W-889mm(35") H-1118mm(44")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±1915 Pa (40 psf) Positive Design Pressure: 1905 Pa (75 psf) Negative Design Pressure: 1905 Pa (75 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.0 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4089-01
Expiration Date: October 31, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122