

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013947.02-R1
DATE: 01/24/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 12/02/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Aurora Custom" Fiberglass In-Swing Transom Configuration: O Glazing: IG-3/16 Tempered Glass/1/8" Annealed Glass/0.090 Kuraray SGP Interlayer/1/8" Annealed Glass Frame: W-2490mm(98.06") H-1321mm(52") DLO: W-2410mm(94.88") H-1240mm(48.81")

SPECIFICATION	PRODUCT RATING
ASTM E330-14/E547-00(16) ASTM E1886-13a ASTM E1996-14a	Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Wind Zone 3 - Missile Level D

Product Tested By: Intertek
Report No: H8907.03-301-47
Expiration Date: January 31, 2027

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shu", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com