

	Document Title: Impact Performance Certification Authorization Report	Doc No: FRM B1-43	
		Rev No: 4	Page: 1 Of: 1
Required By: PRO B1-03			

CAR & Product ID Number: 1071 - 206

Issue Date: 12/21/2017

Revision Date: 12/21/2017

Expiration Date: 12/21/2021

Company Code: 1071

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com.

Licensee Information:	Product Information:
Gaulhofer Industrie-Holding GmbH Guggenbach 7 Ubelbach 8124	Model: Fusionline 94 Outswing Side Hinge Door XX Operator Type: SHD Config: SR, GS-5/16" HS Lami IG Max Width: 83 Max Height: 107 Corresponding Structural CARs: 1071-114

Referenced Standard:	Product Rating:
ASTM E1886-05, ASTM E1996-05	Missile Lever D, Wind Zone 3, DP +/-50, 83x107

Qualifying Test Information:	
Test Report No:	ATI-C2638.01-401-44
Test Report Expiration:	12/21/2021

Authorized Signature:



Aaron Shultz
2017.12.21 09:37:12
-05'00'

Keystone Certifications, Inc.
145 Limekiln Rd., Suite 100B
New Cumberland, Pennsylvania 17070
Phone: 717-932-8500
Fax: 717-932-8501