

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI013981.12-R2
DATE: 04/03/2018
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/03/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Opaque Fiberglass In-Swing Side-Hinged Door Configuration: X Frame: W-950mm(37.38") H-2075mm(81.69") Panel: W-908mm(35.75") H-2006mm(79")

SPECIFICATION	PRODUCT RATING
TAS 202-94 (Structural Only)	Design Pressure: ± 3120 Pa (65 psf) Positive Design Pressure: 3120 Pa (65 psf) Negative Design Pressure: 3360 Pa (70 psf) Water Penetration Resistance Test Pressure: 0 Pa (0 psf)

Product Tested By: Intertek Group, PLC
Report No: I1290.03-301-47
Expiration Date: March 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023