NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI013981.15-R2**
DATE:	**04/03/2018**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**08/03/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**Series "Architectural" Opaque** **Fiberglass Out-Swing Side-Hinged Door** **w/High Dam Sill** Configuration: X Frame: W-1099mm(43.25") H-2448mm(96.38") Panel: W-1059mm(41.69") H-2413mm(95")

SPECIFICATION	PRODUCT RATING
TAS 202-94 **(Structural Only)**	**Design Pressure: ±3120 Pa (65 psf)** **Positive Design Pressure: 3120 Pa (65 psf)** **Negative Design Pressure: 3360 Pa (70 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0 psf)**

Product Tested By: Intertek Group, PLC
Report No: I1290.06-301-47
Expiration Date: **March 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com