

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016380-R1
DATE: 10/30/2024
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/03/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Architectural" Glazed Fiberglass Inswing Side Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1873mm(73.75") H-2075mm(81.69") Panel: W-908mm(35.75") H-2007mm(79") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
TAS 202-94 (Structural Only)	Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)

Product Tested By: Intertek, PLC
Report No: L7734.01-301-47
Expiration Date: October 31, 2030

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023